

3-5. 「新・つくば耐力壁」相当壁倍率一覧表

「新・つくば耐力壁」の相当壁倍率一覧表を P26～P43 に示す。

1) 一覧表から相当壁倍率を選定する方法

・階高：2815mm、梁せい：180mmおよび240mm時における相当壁倍率の選定例

「K型」または「X型」の選択確認  
「筋かいのみ」または「筋かい+面材」の選択確認  
「床合板なし」または「24mm床合板」の選択確認

		新・つくば耐力壁 相当壁倍率一覧															
階高：土台・床梁上端～梁・桁上端とする		150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
梁せい	階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2640	4.61	4.13	4.61	4.13	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2650	4.61	4.13	4.61	4.13	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2660	4.61	4.13	4.61	4.13	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2770	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2780	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2790	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2800	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2810	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2820	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2830	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2840	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2850	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2860	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2870	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2880	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2890	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2900	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09

上の行：2810  
下の行：2820  
階高2815が間に含まれる2行を選択

上の行：4.13  
下の行：4.13  
上下2行の数値が同一の場合  
4.13 (倍) で確定

上の行：4.61  
下の行：4.13  
上下2行の数値が異なる場合  
2)の方法で倍率数値を選定する

2) 横架材間内法寸法を算出し相当壁倍率を選定する方法


次式より横架材間内法寸法：H を算出し、表 7 より相当壁倍率を選定する。

$$H = Fh - Bh - t$$

H：横架材間内法寸法  
Fh：階高  
Bh：梁せい  
t：床合板厚さ(無しの場合は0)

表 7 横架材間内法寸法毎の相当壁倍率

	横架材間内法寸法：H (mm)	相当壁倍率 (倍)
〈 K 型 〉 筋かい仕様	2550 超 ～ 2850 以下	4. 13
	2250 以上～ 2550 以下	4. 61
	1950 以上～ 2250 未満	5. 09
〈 X 型 〉 筋かい仕様	2550 超 ～ 2850 以下	6. 33
	2250 以上～ 2550 以下	7. 00
	1950 以上～ 2250 未満	7. 00
〈 K 型 〉 筋かい+面材仕様	2550 超 ～ 2850 以下	5. 83
	2250 以上～ 2550 以下	6. 37
	1950 以上～ 2250 未満	6. 91



〈K型〉		筋かいのみ			床合板なし		新・つくば耐力壁 相当壁倍率一覧									
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2100	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2110	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2120	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2130	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2140	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2150	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2160	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—
2170	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—
2180	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—
2190	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—
2200	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—
2210	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—
2220	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—
2230	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—
2240	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—
2250	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—
2260	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—
2270	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—
2280	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—
2290	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—
2300	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—
2310	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—
2320	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—
2330	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—
2340	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—
2350	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—
2360	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—
2370	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—
2380	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—
2390	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—
2400	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—
2410	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—
2420	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—
2430	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—
2440	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—
2450	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—
2460	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—
2470	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—
2480	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—
2490	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—
2500	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—
2510	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—
2520	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—
2530	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—
2540	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—
2550	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2560	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2570	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2580	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2590	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2600	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2610	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2620	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2630	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09

[illegible]

〈K型〉	筋かいのみ		床合板なし		新・つくば耐力壁 相当壁倍率一覧											
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
3180	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3190	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3200	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3210	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3220	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3230	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3240	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3250	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3260	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3270	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13
3280	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13
3290	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13
3300	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13
3310	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13
3320	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13
3330	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13
3340	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13
3350	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13
3360	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13
3370	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13
3380	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13
3390	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13
3400	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13
3410	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13
3420	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13
3430	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13
3440	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13
3450	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13

〈K型〉		筋かいのみ			24mm床合板		新・つくば耐力壁 相当壁倍率一覧									
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2100	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2110	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2120	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2130	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2140	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2150	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2160	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2170	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2180	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2190	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—
2200	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—
2210	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—	—
2220	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—
2230	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—
2240	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—	—
2250	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—
2260	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—
2270	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—	—
2280	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—
2290	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—
2300	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—	—
2310	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—
2320	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—
2330	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—	—
2340	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—
2350	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—
2360	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—	—
2370	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—
2380	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—
2390	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—	—
2400	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—
2410	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—
2420	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—	—
2430	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—
2440	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—
2450	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—	—
2460	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—
2470	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—
2480	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—	—
2490	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—
2500	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—
2510	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—	—
2520	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—
2530	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—
2540	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—	—
2550	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—
2560	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—
2570	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	—
2580	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2590	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2600	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2610	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2620	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2630	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09

《K型》		筋かいのみ			24mm床合板		新・つくば耐力壁 相当壁倍率一覧									
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2640	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2650	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2660	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2670	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2680	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2690	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09	5.09
2700	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09
2710	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09
2720	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09	5.09
2730	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09
2740	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09
2750	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09	5.09
2760	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2770	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2780	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09	5.09
2790	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09
2800	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09
2810	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09	5.09
2820	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09
2830	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09
2840	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09	5.09
2850	4.13	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09
2860	4.13	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09
2870	4.13	4.13	4.13	4.13	4.13	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	4.61	5.09
2880	4.13	4.13	4.13	4.13	4.13	4.13	4.61	4.61								

〈K型〉		筋かいのみ			24mm床合板		新・つくば耐力壁										相当壁倍率一覧		
階高：土台・床梁上端～梁・桁上端とする																			
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600			
3180	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3190	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3200	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3210	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3220	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3230	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3240	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3250	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3260	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3270	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3280	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3290	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13	4.13			
3300	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13			
3310	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13			
3320	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13	4.13			
3330	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13			
3340	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13			
3350	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13	4.13			
3360	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13			
3370	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13			
3380	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13	4.13			
3390	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13			
3400	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13			
3410	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13	4.13			
3420	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13			
3430	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13			
3440	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13	4.13			
3450	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	4.13			

〈X型〉		筋かいのみ			床合板なし			新・つくば耐力壁 相当壁倍率一覧									
階高：土台・床梁上端～梁・桁上端とする																	
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600	
2100	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
2110	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
2120	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
2130	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
2140	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
2150	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
2160	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	
2170	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	
2180	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	
2190	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	
2200	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	
2210	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	
2220	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	
2230	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	
2240	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	
2250	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	
2260	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	
2270	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	
2280	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	
2290	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	
2300	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	
2310	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	
2320	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	
2330	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	
2340	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	
2350	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	
2360	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	
2370	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	
2380	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	
2390	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	
2400	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	
2410	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	
2420	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	
2430	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	
2440	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	
2450	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	
2460	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	
2470	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	
2480	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	
2490	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	
2500	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	
2510	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	
2520	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	
2530	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	
2540	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	
2550	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2560	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2570	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2580	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2590	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2600	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2610	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2620	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	
2630	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	



〈X型〉		筋かいのみ		床合板なし		新・つくば耐力壁											相当壁倍率一覧	
階高：土台・床梁上端～梁・桁上端とする																		
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600		
2640	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2650	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2660	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2670	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2680	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2690	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2700	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2710	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2720	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2730	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2740	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2750	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2760	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2770	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2780	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2790	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2800	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2810	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2820	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2830	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2840	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2850	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2860	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2870	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2880	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2890	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2900	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2910	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2920	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2930	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2940	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2950	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2960	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2970	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00		
2980	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00		
2990	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00		
3000	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00		
3010	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00		
3020	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00		
3030	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00		
3040	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00		
3050	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00		
3060	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00		
3070	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00		
3080	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00		
3090	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00		
3100	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00		
3110	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00		
3120	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00		
3130	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00		
3140	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00		
3150	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00		
3160	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33		
3170	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33		

〈X型〉	筋かいのみ		床合板なし		新・つくば耐力壁 相当壁倍率一覧											
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
3180	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3190	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3200	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3210	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3220	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3230	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3240	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3250	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3260	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3270	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3280	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33
3290	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33
3300	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33
3310	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33
3320	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33
3330	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33
3340	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33
3350	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33
3360	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33
3370	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33
3380	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33
3390	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33
3400	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33
3410	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33
3420	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33
3430	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33
3440	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33
3450	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33

〈X型〉		筋かいのみ		24mm床合板		新・つくば耐力壁 相当壁倍率一覧										
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2100	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2110	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2120	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2130	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2140	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2150	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2160	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2170	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2180	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2190	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—
2200	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—
2210	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—	—
2220	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—
2230	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—
2240	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—	—
2250	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—
2260	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—
2270	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—	—
2280	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—
2290	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—
2300	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—	—
2310	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—
2320	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—
2330	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—	—
2340	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—
2350	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—
2360	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—	—
2370	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—
2380	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—
2390	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—	—
2400	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—
2410	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—
2420	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—	—
2430	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—
2440	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—
2450	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—	—
2460	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—
2470	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—
2480	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—	—
2490	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—
2500	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—
2510	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—	—
2520	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—
2530	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—
2540	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—	—
2550	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—
2560	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—
2570	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	—
2580	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2590	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2600	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2610	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2620	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2630	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00

〈X型〉		筋かいのみ			24mm床合板		新・つくば耐力壁 相当壁倍率一覧									
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2640	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2650	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2660	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2670	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2680	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2690	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2700	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2710	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2720	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2730	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2740	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2750	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2760	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2770	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2780	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2790	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2800	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2810	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2820	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2830	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2840	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2850	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2860	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2870	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2880	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2890	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2900	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2910	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2920	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2930	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2940	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2950	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2960	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2970	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2980	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00
2990	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00	7.00
3000	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00
3010	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00
3020	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00	7.00
3030	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00
3040	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00
3050	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00	7.00
3060	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00
3070	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00
3080	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00	7.00
3090	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00
3100	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00
3110	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00	7.00
3120	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00
3130	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00
3140	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00	7.00
3150	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00
3160	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00
3170	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	7.00

〈X型〉		筋かいのみ			24mm床合板		新・つくば耐力壁 相当壁倍率一覧									
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
3180	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3190	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3200	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3210	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3220	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3230	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3240	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3250	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3260	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3270	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3280	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3290	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33	6.33
3300	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33
3310	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33
3320	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33	6.33
3330	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33
3340	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33
3350	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33	6.33
3360	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33
3370	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33
3380	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33	6.33
3390	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33
3400	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33
3410	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33	6.33
3420	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33
3430	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33
3440	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33	6.33
3450	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	6.33

〈K型〉		筋かい+面材	床合板なし	新・つくば耐力壁 相当壁倍率一覧												
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2100	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2110	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2120	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2130	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2140	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2150	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2160	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—
2170	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—
2180	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—
2190	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—
2200	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—
2210	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—
2220	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—
2230	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—
2240	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—
2250	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—
2260	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—
2270	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—
2280	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—
2290	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—
2300	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—
2310	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—
2320	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—
2330	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—
2340	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—
2350	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—
2360	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—
2370	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—
2380	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—
2390	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—
2400	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—
2410	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—
2420	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—
2430	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—
2440	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—
2450	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—
2460	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—
2470	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—
2480	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—
2490	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—
2500	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—
2510	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—
2520	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—
2530	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—
2540	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—
2550	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2560	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2570	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2580	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2590	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2600	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2610	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2620	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2630	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91

〈K型〉		筋かい+面材	床合板なし	新・つくば耐力壁 相当壁倍率一覧												
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2640	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2650	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2660	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2670	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91
2680	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91
2690	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91
2700	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91
2710	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91
2720	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91
2730	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91
2740	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91
2750	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91
2760	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91
2770	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91
2780	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91
2790	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91
2800	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91
2810	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91
2820	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91
2830	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91
2840	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91
2850	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2860	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2870	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2880	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2890	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2900	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2910	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2920	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2930	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2940	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2950	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2960	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2970	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37
2980	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37
2990	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37
3000	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37
3010	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37
3020	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37
3030	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37
3040	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37
3050	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37
3060	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37
3070	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37
3080	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37
3090	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37
3100	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37
3110	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37
3120	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37
3130	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37
3140	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37
3150	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37
3160	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3170	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83

〈K型〉		筋かい+面材		床合板なし		新・つくば耐力壁 相当壁倍率一覧										
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
3180	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3190	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3200	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3210	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3220	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3230	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3240	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3250	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3260	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3270	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83
3280	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83
3290	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83
3300	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83
3310	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83
3320	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83
3330	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83
3340	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83
3350	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83
3360	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83
3370	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83
3380	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83
3390	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83
3400	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83
3410	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83
3420	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83
3430	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83
3440	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83
3450	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83



〈K型〉		筋かい+面材		24mm床合板		新・つくば耐力壁 相当壁倍率一覧										
階高：土台・床梁上端～梁・桁上端とする																
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600
2100	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2110	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2120	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2130	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2140	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2150	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2160	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2170	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2180	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2190	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—
2200	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—
2210	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—	—
2220	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—
2230	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—
2240	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—	—
2250	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—
2260	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—
2270	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—	—
2280	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—
2290	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—
2300	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—	—
2310	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—
2320	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—
2330	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—	—
2340	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—
2350	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—
2360	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—	—
2370	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—
2380	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—
2390	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—	—
2400	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—
2410	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—
2420	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—	—
2430	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—
2440	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—
2450	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—	—
2460	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—
2470	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—
2480	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—	—
2490	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—
2500	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—
2510	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—	—
2520	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—
2530	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—
2540	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—	—
2550	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—
2560	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—
2570	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	—
2580	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2590	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2600	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2610	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2620	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91
2630	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91

〈K型〉		筋かい+面材		24mm床合板		新・つくば耐力壁											相当壁倍率一覧	
階高：土台・床梁上端～梁・桁上端とする																		
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600		
2640	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91		
2650	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91		
2660	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91	6.91		
2670	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91		
2680	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91		
2690	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91	6.91		
2700	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91		
2710	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91		
2720	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91	6.91		
2730	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91		
2740	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91		
2750	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91	6.91		
2760	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91		
2770	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91		
2780	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91	6.91		
2790	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91		
2800	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91		
2810	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91	6.91		
2820	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91		
2830	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91		
2840	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91	6.91		
2850	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91		
2860	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91		
2870	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.91		
2880	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2890	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2900	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2910	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2920	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2930	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2940	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2950	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2960	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2970	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2980	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
2990	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37	6.37		
3000	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37		
3010	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37		
3020	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37	6.37		
3030	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37		
3040	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37		
3050	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37	6.37		
3060	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37		
3070	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37		
3080	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37	6.37		
3090	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37		
3100	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37		
3110	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37	6.37		
3120	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37		
3130	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37		
3140	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37	6.37		
3150	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37		
3160	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37		
3170	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	6.37		

〈K型〉	筋かい+面材			24mm床合板		新・つくば耐力壁 相当壁倍率一覧											
階高：土台・床梁上端～梁・桁上端とする																	
梁せい 階高	150	180	210	240	270	300	330	360	390	420	450	480	510	540	570	600	
3180	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3190	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3200	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3210	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3220	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3230	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3240	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3250	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3260	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3270	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3280	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3290	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	5.83	
3300	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	
3310	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	
3320	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	5.83	
3330	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	
3340	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	
3350	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	5.83	
3360	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	
3370	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	
3380	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	5.83	
3390	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	
3400	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	
3410	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	5.83	
3420	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	
3430	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	
3440	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	5.83	
3450	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	5.83	